



This checklist is used to check documentation and marking in accordance with the standard IEC 62561-2; for metallic conductors (other than "natural" conductors) that form part of the air-termination and down-conductor systems and metallic earth electrodes that form part of the earth-termination system. To comply with the standard, all points on this checklist must be fulfilled.

Documentation

4.2	The manufacturer or supplier of the conductors and earth electrodes shall provide adequate information in their literature to ensure that the installer of the conductors and earth electrodes can select and install the materials in a suitable and safe manner, in accordance with IEC 62305-3 and IEC 62305-4.	available? <input type="checkbox"/>
------------	---	--

Marking

4.5	All products have to be marked at least with:	yes
a)	The manufacturer's or responsible vendor's name or trademark or identifying symbol	<input type="checkbox"/>
	<ul style="list-style-type: none"> • Marking can be applied for example by moulding, pressing, engraving, printing adhesive labels or water slide transfers. • Where this proves to be impractical the marking in accordance with the identifying symbol may be given on the smallest packing unit. 	